		Copper Brute II
Date:	Bid Date:	Water Heater
Project #:	Location:	Water Heater
Project Name:	Engineer:	Model BWCV 500-2000 Indoor/Outdoor
Contractor:	Prepared By:	Specification
	•	
Contractor shall supply and install Oty	ppper Brute II, BWCV water heater(s)	
The heater shall be a BW Copper Brute II, BWCV certified to comply with the current edition of the I certified for both indoor and outdoor use. The un Code, Section IV requirements for 160 psi (1103 comply with the efficiency requirements of the lat The water tube heat exchanger shall be a straigh rolled directly into glass-lined cast iron headers, r design. All gaskets shall be non-metallic, outside deterioration from heat. Headers shall have covered to the content of the straight shall be covered to the shall be covered to the straight shall be covered	rated at the input and output shown armonized ANSI Z21.10.3 / CSA 4.3 Standard fit(s) shall be designed and constructed in accord kPa) working pressure, and shall bear the ASME est edition of ASHRAE Standard 90.1. It tube design with ten 7/8" (22mm) inner diameter ated for 160 psi (1103 kPa) working pressure.	n on the schedule. The unit(s) shall be design for Gas Water Heaters, and shall be design ance with the ASME Boiler & Pressure Vessel "H" Stamp. The unit(s) shall be constructed to er integral finned copper tubes. The tubes shall be the heat exchanger shall be a low water volume chamber by at least 3.5" (89mm) to eliminate
have a ten year warranty. The piping side header shall have removable flanges, and the water heater design shall permit removal of the complete heat exchanger for service		
from either the front or top, to facilitate maintenance. Each unit shall have a pump time delay. The pump time delay shall be adjustable from 20 seconds to 10 minutes for continued pump circulation		
after the call for heat has been satisfied, to remove residual heat from the unit's combustion chamber.		
The units shall use a proved hot surface ignition of flame is not detected, the ignition module shall at signal during a call for heat, the ignition control shall as ASME CSD-1, are built with single-try ignition cor	tempt two more times before locking out, and rec nall attempt three re-ignition cycles before locking	uiring manual reset. If there is a loss of flame out. (BWCV units with some options, such as
Burners shall be multi-port design, and shall be constructed of high temperature stainless steel. The burners shall be designed to mix air and gas, and burn cleanly with NOx emissions not exceeding 10ppm. Burners shall be in easily-removable burner tray assemblies with no more than 4 burners per tray.		
The combustion chamber shall be lined with lightweight, ceramic fiberboard insulation to retain heat, and shall be approved for service temperatures of not less than 2000°F (1093°C). The outer jacket shall be a unitized shell finished with acrylic thermo-set paint baked at not less than 325°F (163°C). The frame shall be constructed of galvanized steel for strength and protection. Chamber shall include a sight glass for viewing flame.		
Heaters shall have a forced draft design and shal B-vent as a fan-assisted Category I appliance, ar The unit shall accept ducted combustion air, or sl able to be piped to either the top or the back of the shall be easily accomplished in the field.	l be rated at 85% thermal efficiency. The unit sh id for horizontal venting as a Category III applian nall be able to pull combustion air from the room.	all be designed for vertical venting with standard ce and shall not require an external draft hood. Vent and ducted combustion air shall each be
control or a field-supplied staging control, without	ging control, and a selector switch to enable the of bypassing any of the heater's safety controls. The tage 1, stage 2, stage 3 (if applicable), stage 4 (if some control panels. Additional diagnostic lights for control panels be easily accessed in the control panels.	user to choose between the water heater's staging he heater display shall have diagnostic lights f applicable) and service. The heater display shall or service (low water flow, blocked flue, low air of panel. Dry alarm contacts for ignition failure
Unit(s) shall have multiple gas trains, such that ex shutoff valve and main gas valve with built-in redi to permit easy removal of the each gas valve, gas	undant valve seats and gas regulator. Unions sh	all be used before and after each main gas valve,
The heater shall be provided with an integral, was blower(s) from debris. The air filter shall be cons		ovide 83% arrestence to protect the burners and
Heater shall include as standard equipment the fo		
 ASME 160 psi working pressure heat exchanger 	Manual "A" gas valveIntake air filter	 Automatic reset high limit Electronic PID staging control with LCD and
ASME "H" stamp	 Multiple, removable burner trays 	touchpad
Flanged water connectionsGlass-lined cast iron headers	 Stainless steel burners Built-in draft fan(s) for Category I or III 	 PC board for electrical connections External controller connections with selector
 External header gaskets 	venting	switch
 125 psi (861 kPa) ASME rated pressure relief valve 	Air pressure switchBurner site glass	Hot surface ignitionOn/Off toggle switch
Flow switchTemperature and pressure gauge	24V control system115/24VAC transformer	Pump time delayDiagnostic lights



Temperature and pressure gauge Multiple operating gas valve/pressure

regulators

200 Lafayette St. Middleville, MI 49333 Warranty: (800) 531-2111

Manual reset high limit