		<b>Copper Brute II</b>
Date:	Bid Date:	<b>Hydronic Boiler</b>
Project #:	Location:	nyulullic bullel
Project Name:	Engineer:	Model BWCH 500-2000 Indoor/Outdoor
Contractor:	Prepared By:	Specification
	•	
Contractor shall supply and install Qty.: Co The boiler shall be a Bradford White Copper Brute certified to comply with the current edition of the I- Boilers, and shall be design certified for both indo Boiler & Pressure Vessel Code, Section IV require shall be constructed to comply with the efficiency The water tube heat exchanger shall be a straight rolled directly into glass-lined cast iron headers, re design. All gaskets shall be non-metallic, outside	II, BWCH, rated at the input and output darmonized ANSI Z21.13 / CSA 4.9 Standard for or and outdoor use. The unit(s) shall be designed ements for 160 psi (1103 kPa) working pressure, a requirements of the latest edition of ASHRAE Stattube design with ten 7/8" (22mm) inner diameter ated for 160 psi (1103 kPa) working pressure. The jacket, and separated from the combustion of	Gas-Fired Low Pressure Steam and Hot Water d and constructed in accordance with the ASME and shall bear the ASME "H" Stamp. The unit(s) undard 90.1.  Integral finned copper tubes. The tubes shall be heat exchanger shall be a low water volume hamber by at least 3.5" (89mm) to eliminate
deterioration from heat. Headers shall have covers permitting visual inspection and cleaning of all internal surfaces. The heat exchanger shall have a ten year warranty.  The piping side header shall have removable flanges, and the boiler design shall permit removal of the complete heat exchanger for service from		
either the front or top, to facilitate maintenance.  Each unit shall have a pump time delay. The pump time delay shall be adjustable from 20 seconds to 10 minutes for continued pump circulation		
after the call for heat has been satisfied, to remove The units shall use a proved hot surface ignition of flame is not detected, the ignition module shall attained during a call for heat, the ignition control shall attained as ASME CSD-1, are built with single-try ignition controls.	with a 15 second pre-purge cycle to clean out the tempt two more times before locking out, and requal attempt three re-ignition cycles before locking	combustion chamber. Upon a call for heat, if a uiring manual reset. If there is a loss of flame out. (BWCH units with some options, such as
Burners shall be multi-port design, and shall be constructed of high temperature stainless steel. The burners shall be designed to mix air and gas, and burn cleanly with NOx emissions not exceeding 10ppm. Burners shall be in easily-removable burner tray assemblies with no more than 4 burners per tray.		
The combustion chamber shall be lined with lightweight, ceramic fiberboard insulation to retain heat, and shall be approved for service temperatures of not less than 2000°F (1093°C). The outer jacket shall be a unitized shell finished with acrylic thermo-set paint baked at not less than 325°F (163°C). The frame shall be constructed of galvanized steel for strength and protection. Chamber shall include a sight glass for viewing flame.		
Boilers shall have a forced draft design and shall be rated at minimum 85% combustion efficiency. The unit shall be designed for vertical venting with standard B-vent as a fan-assisted Category I appliance and for horizontal venting as a Category III appliance and shall not require an external draft hood. The unit shall accept ducted combustion air, or shall be able to pull combustion air from the boiler room. Vent and ducted combustion air shall each be able to be piped to either the top or the back of the unit, in any combination. Changing from top-to-back or from back- to-top piping orientation shall be easily accomplished in the field.		
Temperature control shall be an electronic PID tel have connections for an external staging control, supplied staging control, without bypassing any of on, call for heat, pump on, stage 1, stage 2, stage removal of any jacket panels or control panels. A low air flow — blower 2 (if applicable)) shall be ea Models 500 and 750 shall be two-stage firing, mo	and a selector switch to enable the user to choose fithe boiler's safety controls. The boiler display she 3 (if applicable), stage 4 (if applicable) and service dditional diagnostic lights for service (low water flessily accessed in the control panel. Dry alarm con	e between the boiler's staging control or a field- nall have diagnostic lights which include power ce. The boiler display shall be visible without the ow, blocked flue, low air flow — blower 1, and stacts for ignition failure shall be included.
Unit(s) shall have multiple gas trains, such that ea shutoff valve and main gas valve with built-in redu to permit easy removal of the each gas valve, gas	undant valve seats and gas regulator. Unions sha	all be used before and after each main gas valve,
The boiler shall be provided with an integral, wash blower(s) from debris. The air filter shall be const		ride 83% arrestence to protect the burners and
Boiler shall include as standard equipment the fol  ASME 160 psi working pressure heat exchanger  ASME "H" stamp  Flanged water connections  Glass-lined cast iron headers  External header gaskets  75 psi (517 kPa) ASME rated pressure relief valve  Flow switch  Temperature and pressure gauge  Multiple operating gas valve/pressure	lowing controls and trim:  Manual "A" gas valve Intake air filter  Multiple, removable burner trays Stainless steel burners Built-in draft fan(s) for Category I or III venting Air pressure switch Burner site glass 24V control system 115/24VAC transformer Manual reset high limit	<ul> <li>Automatic reset high limit</li> <li>Electronic PID staging control with LCD and touchpad</li> <li>PC board for electrical connections</li> <li>External controller connections with selector switch</li> <li>Hot surface ignition</li> <li>On/Off toggle switch</li> <li>Pump time delay</li> <li>Diagnostic lights</li> </ul>



regulators