



Architectural Design Series Concealed Flush Valve

1800D90TR-19-BL

Description0.5 gpf (1.9 Lpf) Flush Volume, Infrared Sensor, Matte Black Finish, Hardwire

0.5 gpf (1.9 Lpf) Flush Volume, Infrared Sensor, Matte Black Finish, Hardwire Operated, Urinal Fixture, Electronic Manual Override, Front Accessible Rough-In Box

Specifications

Flush Volume: Fixed @ 0.5 gpf (1.9 Lpf)

Sensor Type: InfraredFinish: Matte Black

 Power Supply: Hardwire Operated (24 VAC) requires transformer (sold separately)

separately)

Fixture Type: Urinal

Override: Electronic ManualRough-In Box: Front Accessible

Features

- · Cover with integral sensor
- · Vandal-resistant mounting plate, installed with single hidden screw
- · No visible mounting hardware
- · TRIM MODELS Supplied as sensor and override button attached to cover
- · Preset blocking time, built-in activation delay
- Oversized ADA compliant push button

Required Accessories

- 060704A Transformer 120 to 24 VAC Class 2 20 VA
- 060771A Transformer 120 to 24 VAC Class 2 40 VA

Optional Accessories

 061704A - Hardwire with Battery Backup - (See DSP-BB for detailed specification)



Complies With

- ASSE 1037/ ASME A112.1037/ CSA B125.37
- ICC/ANSI A117.1
- EPA WaterSense®





(Contact Delta Representative for State and/or Local Approvals)

Operation

- · Hands free touch-less operation
- · Power function light
- · Adjustable 24 hours courtesy flush
- Selectable sensing distance 12" to 28" (305 to 711 mm) in 4" (102 mm) increments factory set to 20" (508 mm)
- · 12 seconds blocking time

Notes


Rough-in (1800D90RI) ordered separately






Architectural Design Series Concealed Flush Valve

1800D90TR-19-BL





Delta Commercial flushometer valves are designed to operate at a supply pressure between 20 psi and 125 psi in accordance with ASSE 1037/ASME A112.1037/CSA B125.37. At high water pressures, splash out, noise or reduced life of plumbing components may be observed with a few models of water closet or urinal fixtures. To minimize, or eliminate these effects, select a different model of water closet or urinal fixture from the same or different manufacturer, or install a pressure reducing valve. If the installation does not allow for either of these options, the ball valve adjustment may be used to reduce peak flow to the valve.